























# SINGLE BOILER PRIMARY/SECONDARY WITH 3-WAY VALVE

260 North Elm Street - Westfield, MA 01089  
413.568.9571 fax 413.568.1178

Hydronic Piping H-7

Boiler connection Pipe Sizing and Heat Exchanger Configuration		
Heater Model	Pipe size NPS	Configurations
50-400	1 1/2"	Two Pass
420-1900	2 1/2"	Two Pass
2000-4000	3"	Two Pass
Dominator	2 1/2"	Two Pass
Futura	2 1/2"	Four Pass

-  Pump
-  Gate Valve
-  Globe Valve
-  Angle Valve
-  Butterfly Valve
-  Circuit Setter
-  Ball Valve
-  Motorized Valve
-  Solenoid Operated Valve
-  Self-Operated Valve
-  Pressure Reducing Valve
-  Check Valve
-  Pressure Relief Valve
-  Flow Switch
-  Thermometer
-  Aquastat Union
-  Pressure Switch
-  Gas Pressure Regulator
-  Automatic Air Vent



**NOTES:**

1. Primary/Secondary required for variable flow systems.
2. Boiler circuit piping must equal boiler connection size.
3. Boiler Pump sized to boiler design flow requirements.
4. Boiler water connection (inlet/outlet) vary per model. Verify connection orientation.
5. All boilers furnished with factory mounted outlet water temperature gauge.
6. Dotted symbols indicate optional locations.
7. Boiler Pump requires system temp Interlocks.
8. CWMU = Cold Water Make-Up.
9. Temperature sensors require field interlocks to boiler control.

Notice: This drawing shows suggested piping configuration and valving.  
Check with local codes and ordinances for additional requirements.