

INTAKE SIZES		AIR INTAKE ACCEPTABLE MATERIALS	
MODEL	THRU WALL & VERTICAL	"A"	
500	8" DIA.	37 1/2	SINGLE WALL GALVANIZED SMOKE PIPE
750	10" DIA.	43 3/4	SINGLE WALL ALUMINUM PIPE
1000	10" DIA.	51"	FLEXIBLE ALUMINUM PIPE
1250	12" DIA.	43 1/2	PVC OR CPVC PIPE
1500	12" DIA.	49"	
1750	14" DIA.	53 1/4	
1950	14" DIA.	57 3/4	

FUTERA II


**TOLERANCES**  
 (UNLESS OTHERWISE SPECIFIED)  
 ± 1/32 ON FRACTIONAL DIM'S.  
 ± .005 ON DECIMAL DIM'S.  
 DRAFT: 2 MAX (SEE NOTE 2)  
 ± .25° ON ANGLE DIM'S.

THIS PRINT AND ALL INFORMATION APPEARING THEREON IS THE PROPERTY OF THE FBI DIVISION OF WESTEK INC. NEITHER THE PRINT NOR THE INFORMATION THEREON MAY BE REPRODUCED OR USED IN ANY MANNER WHATSOEVER WITHOUT THE EXPRESS WRITTEN PERMISSION OF WESTEK INC. AUTHORIZED BY WESTEK INC.



FUTERA II  
 AIR INTAKE & VENTING  
 DIMENSION SIZES

SCALE: NONE	SHEET: 1 OF 1	DWG. SIZE: B	DRAWING NUMBER: XX-XXXX	REV: V
DR. BY: DRP	DATE: 11/18/02	CK. BY: XXX	DATE: XX/XX/XX	



DIRECT OR SIDE-WALL VENT ACCEPTABLE MATERIALS	VERTICAL AND CHIMNEY VENTS
UL 1738 CERTIFIED VENT SYSTEM (USA)	APPROVED METAL CHIMNEY
ULS636 CERTIFIED VENT SYSTEM (CANADA)	PROPERLY SIZED MASONRY CHIMNEY

OUTLET SIZES			
MODEL	THRU WALL DIAMETER	VERTICAL DIAMETER	"B"
500	6"	8"	11 1/2
750	8"	10"	14 3/4
1000	9"	10"	18"
1250	10"	12"	17"
1500	10"	12"	18 7/8
1750	12"	14"	20 7/8
1950	12"	14"	26 5/8